




BV LCIE 1966AS10HRR33059  
CHINA  
Number 1966AF10HRR33059

## ATTESTATION of conformity with European Directives

*Product:* **Split type air conditioner**  
*Reference* **RPFC-3.5UFE1NH (Indoor unit) with RAS-3.5UFESNH1 (Outdoor unit)  
RCI-3.5UFE1NH (Indoor unit) with RAS-3.5UFESNH1 (Outdoor unit)  
RPIH-3.5UFE1NH (Indoor unit) with RAS-3.5UFESNH1 (Outdoor unit)**  
*Issued to* **Hitachi-Johnson Controls Air Conditioning, Inc.**  
*Address* **1-16-1, Kaigan Minato-ku, Tokyo, Japan**  
*Manufacturer* **Hitachi-Johnson Controls Air Conditioning, Inc.**  
*Technical characteristics* **220-240V, 50Hz, 4100W, 18,0A, Class I, IPX4 for outdoor unit, Max.  
Discharge pressure: 4,3MPa, Max. Suction pressure: 1,6MPa,  
R32/1,45Kg,**



The submitted sample of the above equipment has been tested for  marking according to following European Directive and following standards:

- Low Voltage Directive 2014/35/EU

<i>Standards</i>	<i>Report number</i>	<i>Report date</i>
<b>EN 60335-1:2012 +A11:2014 +A13:2017 EN 60335-2-40:2003 +A11:2004 +A12:2005 +A1:2006 +A2:2009 +A13:2012 EN 62233:2008</b>	<b>HRR-19OC1580DTQDP</b>	<b>30/10/2019</b>

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product

The  marking may be affixed if all relevant and effective European Directives with  are applicable

Shanghai (P.R. China), Oct. 30<sup>th</sup>, 2019

**Yi ZONG**  
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.  
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA  
上海欧亚电气技术咨询服务有限公司

Building 4, No. 518, Xin Zhuan Road, CaoHejing  
Songjiang High-Tech Park, Shanghai P.R.C  
(201612)

Tel: +86 21 6195 7000  
Fax: +86 21 6195 7001  
Email: contact@cn.bureauveritas.com

Version 3/2016.02.19