



LCIE

BV LCIE 1966AS10HRR33060
CHINA
Number 1966AF10HRR33060

ATTESTATION of conformity with European Directives

Product: **Ceiling & Floor Type Air Conditioner**
Reference **RPFC-4.0UFE1NH (Indoor unit) with RAS-4.0UFESNH1 (Outdoor unit)**
Issued to **Hitachi-Johnson Controls Air Conditioning, Inc.**
Address **1-16-1, Kaigan Minato-ku, Tokyo, Japan**
Manufacturer **Hitachi-Johnson Controls Air Conditioning, Inc.**
Technical characteristics **220-240V~, 50Hz, 5100W, 22,5A, Class I, IPX4 for outdoor unit, Max. Discharge pressure: 4,3MPa, Max. Suction pressure: 1,6MPa, R32, 2,0kg,**

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

<i>Standards</i>	<i>Report number</i>	<i>Report date</i>
EN 60335-1:2012 +A11:2014 +A13:2017 EN 60335-2-40:2003 +A11:2004 +A12: 2005 +A1:2006 +A2:2009 +A13:2012 EN 62233:2008	HRR-19OC1582DTQDP	30/10/2019

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), Oct.30th, 2019

Yi ZONG
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA

必维欧亚电气技术咨询服务(上海)有
限公司

Version 3/2016.02.19

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com



LCIE

BV LCIE 1966AS10HRR33061
CHINA
Number 1966AF10HRR33061

ATTESTATION of conformity with European Directives

Product: **Cassette Type Air Conditioner**

Reference **RCI-4.0UFE1NH (Indoor unit) with RAS-4.0UFESNH1 (Outdoor unit)**

Issued to **Hitachi-Johnson Controls Air Conditioning, Inc.**

Address **1-16-1, Kaigan Minato-ku, Tokyo, Japan**

Manufacturer **Hitachi-Johnson Controls Air Conditioning, Inc.**

Technical characteristics **220-240V~, 50Hz, 5100W, 22,5A, Class I, IPX4 for outdoor unit, Max. Discharge pressure: 4,3MPa, Max. Suction pressure: 1,6MPa, R32, 2,0kg,**

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

Standards	Report number	Report date
EN 60335-1:2012 +A11:2014 +A13:2017 EN 60335-2-40:2003 +A11:2004 +A12:2005 +A1:2006 +A2:2009 +A13:2012 EN 62233:2008	HRR-19OC1584DTQDP	30/10/2019

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), Oct.30th, 2019

Yi ZONG
Product Line Manager



This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
Information given in this document, are related to the tested specimen of the described electrical sample.

LCIE CHINA
必维欧亚电气技术咨询服务(上海)有限公司

Building 4, No. 518, Xin Zhuan Road,
CaoHejing Songjiang High-Tech Park,
Shanghai P.R.C (201612)

Tel: +86 21 6195 7000
Fax: +86 21 6195 7001
Email: contact@cn.bureauveritas.com



BV LCIE 1966AS10HRR33062
 CHINA
 Number 1966AF10HRR33062

LCIE

ATTESTATION of conformity with European Directives

Product: **Duct Type Air Conditioner**
Reference **RPIH-4.0UFE1NH (Indoor unit) with RAS-4.0UFESNH1 (Outdoor unit)**
Issued to **Hitachi-Johnson Controls Air Conditioning, Inc.**
Address **1-16-1, Kaigan Minato-ku, Tokyo, Japan**
Manufacturer **Hitachi-Johnson Controls Air Conditioning, Inc.**
Technical characteristics **220-240V~, 50Hz, 5100W, 22,5A, Class I, IPX4 for outdoor unit, Max. Discharge pressure: 4,3MPa, Max. Suction pressure: 1,6MPa, R32, 2,0kg,**

The submitted sample of the above equipment has been tested for **CE** marking according to following European Directive and following standards:

Low Voltage Directive 2014/35/EU

<i>Standards</i>	<i>Report number</i>	<i>Report date</i>
EN 60335-1:2012 +A11:2014 +A13:2017 EN 60335-2-40:2003 +A11:2004 +A12:2005 +A1:2006 +A2:2009 +A13:2012 EN 62233:2008	HRR-19OC1585DTQDP	30/10/2019

The referred test report(s) show that the product complies with standard(s) recognized as giving presumption of compliance with the essential requirements in the specified European Directive

This verification does not imply assessment of the production of the product
 The **CE** marking may be affixed if all relevant and effective European Directives with **CE** are applicable

Shanghai (P.R. China), October 30, 2019

Yi ZONG
Product Line Manager



**This document shall not be reproduced, except in full, without the written approval of BV LCIE China.
 Information given in this document, are related to the tested specimen of the described electrical sample.**

LCIE CHINA
 必维欧亚电气技术咨询服务(上海)有限公司
Version 3/2016.02.19

**Building 4, No. 518, Xin Zhuan Road,
 CaoHejing Songjiang High-Tech Park,
 Shanghai P.R.C (201612)**

Tel: +86 21 6195 7000
 Fax: +86 21 6195 7001
 Email: contact@cn.bureauveritas.com